



**DECLARATION OF PERFORMANCE**  
**According to Construction Products Regulation EU No. 305/2011**  
**No. 105 / 10.06.2020**

1. Unique identification code of the product-type:

**FD7150**

**Batch number: see packaging of the product**

2. Intended use/es:

**Fire detection and fire alarm systems installed in buildings**

**Interactive addressable manual call point with built-in line isolator**

3. Manufacturer:

**UniPOS Ltd.,**

**47 San Stefano Street, 5800, Pleven, Bulgaria**

4. Authorised representative:

**Not relevant**

5. System/s of AVCP:

**System 1**

6. a) Harmonized standard:

**EN 54-11 : 2001 /A1: 2005 - Fire detection and fire alarm systems - Manual call points**

**EN 54-17: 2005 / AC: 2007 - Fire detection and fire alarm systems - Short-circuit isolators**

**EVPU notified body 1293 performed type testing and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control under system 1 and issued the EC certificates of conformity:**

**1293-CPR-0674**

7. Declared performance

Essential characteristics	Performance	Harmonized Technical Specification
		EN54-17: 2005 / AC: 2007
Response delay (response time)	Pass	NA
Performance under fire condition	Pass	cl. 5.2
Operational reliability	Pass	cl. 4
Durability of operational reliability and response delay : Temperature resistance	Pass	cl. 5.4, 5.5
Durability of operational reliability, Vibration resistance	Pass	cl. 5.9 to 5.12
Durability of operational reliability, Humidity resistance	Pass	cl. 5.6, 5.7
Durability of operational reliability, Corrosion resistance	Pass	cl. 5.8
Durability of operational reliability, Electrical stability	Pass	cl. 5.3, 5.13

Essential characteristics	Performance	Harmonized Technical Specification
		EN54-11: 2001/ A1 :2005
Performance under fire condition	Pass	cl. 4.3.2, 4.4, 4.7.1, 4.7.4=N/A, 5.2, 5.3
Operational reliability	Pass	cl. 4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 4.8, 5.4, 5.5
Durability of operational reliability and response delay : Temperature resistance	Pass	cl. 5.7, 5.8=N/A, 5.9
Durability of operational reliability, Humidity resistance	Pass	cl. 5.10, 5.11=N/A, 5.12, 5.19=N/A
Durability of operational reliability, Corrosion resistance	Pass	cl. 5.11=N/A, 5.13
Shock and vibration resistance	Pass	cl. 5.14 to 5.17
Durability of operational reliability, Electrical stability	Pass	cl. 5.6, 5.18
Resistance to ingress	Pass	NA

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Hristo Dimitrov, Chief Executive  
(name)

Pleven, 10.06.2020  
(place and date of issue)

Signature \_\_\_\_\_



Chief Executive