



NOTIFIED BODY No. 1293

EC - CERTIFICATE OF CONFORMITY

No. 1293 – CPD – 0275 of March 9, 2012

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive – CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

Fire detection and fire alarm systems – Optical smoke detector FD 3030

with accessories: 3000 – Socket detector without relay board, Schottky diode or resistor, 3000D – Socket detector with Schottky diode, 3000R – Socket detector with relay board, 3000DR – Socket detector with Schottky diode and resistor is intended for connection to control and indicating equipment, having declared unification with it and is supplied from it

placed on the market by

UniPOS Ltd. Grenaderska Str. 114, 5800 Pleven, Bulgaria

and produced in the factory

UniPOS Ltd., San Stefano Str. 47, 5800 Pleven, Bulgaria

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the approved body EVPÚ a.s., Notified Body No. 1293 has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the Standard (resp. in)

EN 54-7:2000/A2:2006

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on March 9, 2012 and remains valid as long as the conditions laid down in the harmonized technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.



Marek Hudák

The **1293**

Marking may only be used if conformity with all relevant and effective Directives of EP and Council is attested.

040676

EVPÚ a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, www.evpu.sk

Page 1/1 FCO 69-07 rev.3