

# INSPECTION REPORT 06/INEM/039-1

**SGS Bulgaria Ltd.**  
25A, Tsar Osvoboditel Blvd.  
1504 Sofia/Bulgaria  
Tel.: (359-2) 910 15  
Fax: (359-2) 981 81 43  
E\_mail: [sgs\\_bulgaria@sgs.com](mailto:sgs_bulgaria@sgs.com)



# SGS

April 27, 2006

## INSPECTION REPORT Ref: 06/INEM/039-1

IN PURSUANCE OF AN ORDER RECEIVED FROM UNIPOS OOD, REQUESTING US TO CARRY OUT THE INSPECTION WITHIN THE SUBJECT AND SCOPE DESCRIBED AS FOLLOWS:

### 1. SUBJECT OF THE INSPECTION

Fire Control Panel type FS 6000, presented at "Plemed" EOOD Test Laboratory in Pleven/Bulgaria.

### 2. SCOPE OF THE INSPECTION

- Identification of Fire Control Panel, as described herein above, by visual inspection and presented technical documentation and data (manufacturer, type, serial numbers);
- Witness the test of Fire Control Panel for compliance with the requirements of:
- EN 54-2:1997/ AC:1997 clauses 6; 7; 8; 9; 10; 15.2; 15.4; 15.5 and 15.6;
- EN 54-4:1997/ AC 1999 clauses 5; 9.2 and 9.3.

### 3. RESULTS OF THE INSPECTION

Tests of Fire Control Panel was performed from April 10<sup>th</sup> to April 14<sup>th</sup>, 2006 at "Plemed" EOOD Test Laboratory in Pleven, No 114, "Grenaderska" Street, Bulgaria.

The test was performed by Mr. Stanoev, Mr. Chorbadjiev, from Test Laboratory and Mr. Angelov, from UNIPOS OOD, observed by Mr. Ganov, representative of SGS Bulgaria Ltd. and approved by Mr. Borissov -SGS Bulgaria Ltd.

Fire Control Panels, presented for inspection, were identified as type FS 6000. The serial numbers of the goods are listed below:

Fire Control Panel	FS 6000
Serial Numbers	563/ 2006 565/ 2006 568/ 2006
Nominal Supply	220 /230 V, 50Hz
Backup Battery	24V (2x12V Lead Batteries)

SGS representative witnessed the test of a Fire Control Panel, with the below-described details, stated to be representative sample of production, for compliance with the requirements of the following standards:

- EN 54-2:1997 – Fire detection and fire alarm systems – clauses 6; 7; 8; 9; 10; 15.2; 15.4; 15.5 and 15.6
- EN 54-4:1997 – Fire detection and fire alarm systems, clauses 5, 9.2, 9.3, 9.5 and 9.6.

