

CERTIFICATE

of constancy of performance

1922 - CPR - 1737

In compliance with Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Fire detection and fire alarm systems. Smoke detectors - Point smoke detectors that operate using scattered light, transmitted light or ionization. Short-circuit isolators. Interactive addressable optical-smoke detector with built-in line isolator, model: FD7130M, with mounting base 7100

(with the performance listed, see Annexes I and II to 1922-CPR-1737 that are an inseparable part of this certificate)

placed on the market under the name or trade mark of **UniPOS Ltd.**



47 San Stefano Str., 5800 Pleven, Bulgaria

and produced in the manufacturing plant of

UniPOS Ltd.


47 San Stefano Str., 5800 Pleven, Bulgaria

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-7:2018 and EN 54-17:2005, EN 54-17:2005/AC:2007

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 21.03.2022 and will remain valid until 01.12.2025 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. The certificate is supported through annual surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address www.dedal-bg.net.



Manager: *Anna Vasileva*

Issued:
Burgas, 14 October 2022

Ref. No. 02-00

dipl. eng. Anna Vasileva

ANNEX I TO CERTIFICATE OF CONSTANCY OF PERFORMANCE 1922 - CPR - 1737/14.10.2022 (page 1 of 1)

Performance list, acc. to EN 54-7:2018

Essential Characteristics	Performance	Clause
Operational reliability		
- Individual alarm indication	Pass	4.2.1
- Connection of ancillary devices	Pass	4.2.2
- Monitoring of detachable detectors	Pass	4.2.3
- Manufacturer's adjustments	Pass	4.2.4
- On site adjustment of response behaviour	Pass	4.2.5
- Protection against the ingress of foreign bodies	Pass	4.2.6
- Responce to slowly developing fires	Pass	4.2.7
- Software controlled detector (when provided)	Pass	4.2.8
Nominal activation conditions / Sensitivity		
- Repeatability	Pass	4.3.1
- Directional dependence	Pass	4.3.2
- Reproducibility	Pass	4.3.3
Responce delay (responce time)		
- Air movement	Pass	4.4.1
- Dazzling	Pass	4.4.2
Tolerance to supply voltage		
- Variation in supply parameters	Pass	4.5
Performance parameters under fire conditions:		
- Fire sensitivity	Pass	4.6
Durability of Nominal activation condition/ Sensitivity		
Temperature resistance		
- Cold (operational)	Pass	4.7.1.1
- Dry heat (operational)	Pass	4.7.1.2
Humidity resistance		
- Damp heat, steady - state (operational)	Pass	4.7.2.1
- Damp heat, steady - state (endurance)	Pass	4.7.2.2
Corrosion resistance		
- Sulphur dioxide (SO ₂) corrosion (endurance)	Pass	4.7.3
Vibration Resistance		
- Shock (operational)	Pass	4.7.4.1
- Impact (operational)	Pass	4.7.4.2
- Vibration, sinusoidal (operational)	Pass	4.7.4.3
- Vibration, sinusoidal (endurance)	Pass	4.7.4.4
Electrical stability		
- EMC, immunity (operational)	Pass	4.7.5



Manager:

Asacuneva

Issued:
Burgas, 14 October 2022

Ref. No. 02-00

dipl. eng. Anna Vasileva

ANNEX II TO CERTIFICATE OF CONSTANCY OF PERFORMANCE 1922-CPR-1737/ 14.10.2022

Performance list, acc. to EN 54-17:2005, EN 54-17:2005/AC:2007

Essential Characteristics	Performance	Clause
Performance under fire conditions		
- Reproducibility	Pass	5.2
Operational reliability		
- Requirements	Pass	4
Durability of operational reliability, temperature resistance		
- Dry heat (operational)	Pass	5.4
- Cold (operational)	Pass	5.5
Durability of operational reliability, vibration resistance		
- Shock (operational)	Pass	5.9
- Impact (operational)	Pass	5.10
- Vibration, sinusoidal (operational)	Pass	5.11
- Vibration, sinusoidal (endurance)	Pass	5.12
Durability of operational reliability, humidity resistance		
- Damp heat, cyclic (operational)	Pass	5.6
- Damp heat, steady state (endurance)	Pass	5.7
Durability of operational reliability, corrosion resistance		
- Sulphur dioxide (SO ₂) corrosion (endurance)	Pass	5.8
Durability of operational reliability, electrical stability		
- Variation of supply parameters	Pass	5.3
- Electromagnetic compatibility (EMC), immunity tests (operational)	Pass	5.13



Manager: *Азасинева*

Issued:
Burgas, 14 October 2022

Ref. No. 02-00

dipl. eng. Anna Vasileva