



NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0678

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011* (the Construction products Regulation or CPR), this certificate applies to the construction product

Fire detection and fire alarm systems Interactive addressable fire alarm panel IFS 7002

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

UniPOS Ltd.

San Stefano str. 47, 5800 Pleven, Bulgaria

and produced in the manufacturing plant

UniPOS Ltd.

San Stefano str. 47, 5800 Pleven, Bulgaria

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-2: 1997
EN 54-2: 1997/AC: 1999
EN 54-2: 1997/A1: 2006
EN 54-4: 1997
EN 54-4: 1997/AC: 1999
EN 54-4: 1997/A1:2002
EN 54-4: 1997/A2: 2006


under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on January 20th, 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Nová Dubnica, January 20th, 2020

053491



Marek Hudák
Director NB

Annex to Certificate No. 1293 - CPR – 0678 from January 20th, 2020

Technical specifications:

Interactive Addressable Fire control panels IFS 7002 is designed to operate with addressable automatic fire detectors and manual call points. It controls addressable executive devices integrated into fire alarm loops. The addressable executive devices can be power supplied from the fire alarm loop or from a power loop. The panel has outputs provided for integration of external executive devices.

Products parameters:

Power supply -Voltage	220 / 230 VAC
Frequency	50 Hz
Operational temperature	-5°C + +40°C
Relative humidity	to 93%
Protection degree	IP 30
Dimensions	480 x 445 x 100 mm
Weight (without batteries)	7.1 kg


Essential characteristics	Harmonised technical specification		Performance
	EN 54-2:1997 EN 54-2:1997/ AC:1999 EN 54-2:1997/ A1:2006	EN 54-4:1997 EN 54-4:1997/ AC:1999 EN 54-4:1997/ A1:2002 EN 54-4:1997/ A2:2006	
Response delay (response time to fire)	cl. 7.1, 7.7, 7.11=N/A, 7.12=N/A	-	Pass
Performance under fire conditions	cl. 4, 5, 7	-	Pass
Performance of power supply	-	cl. 4, 5, 6	Pass
Operational reliability	cl. 4, 5, 6, 7, 8, 9, 10, 11=N/A, 12, 13, 14	cl. 4, 5, 6, 7, 8	Pass
Durability of operational reliability: temperature resistance	cl. 15.4	cl. 9.5	Pass
Durability of operational reliability: vibration resistance	cl. 15.6, 15.7, 15.15	cl. 9.7, 9.8, 9.15	Pass
Durability of operational reliability: electrical stability	cl. 15.8, 15-9 to 15.12=N/A, 15.13	cl. 9.9, 9.10 to 9.13=N/A	Pass
Durability of operational reliability: humidity resistance	cl. 15.5, 15.14	cl. 9.6, 9.14	Pass

History of certification

No.	Certificate No.	Description	Date of issue
1	1293-CPD-0086	Original certificate issued	June 11 th , 2008
2	1293-CPD-0219	Added place of factory	January 10 th , 2011
3	1293-CPD-0292	Changed place of factory	March 9 th , 2012
4	1293-CPR-0678	CPR certificate issued Change of address	January 20 th , 2020

Nová Dubnica, January 20th, 2020




 Marek Hudák
 Director NB