



NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0674

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011* (the Construction products Regulation or CPR), this certificate applies to the construction product

Fire detection and fire alarm systems Interactive addressable manual call point with built-in line isolator FD 7150

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

UniPOS Ltd.

San Stefano str. 47, 5800 Pleven, Bulgaria

and produced in the manufacturing plant

UniPOS Ltd.

San Stefano str. 47, 5800 Pleven, Bulgaria

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-11: 2001
EN 54-11: 2001/A1: 2005
EN 54-17: 2005
EN 54-17: 2005/AC: 2007

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on January 20th, 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Nová Dubnica, January 20th, 2020

053487



Marek Hudák
Director NB

Annex to Certificate No. 1293 - CPR – 0674 from January 20th, 2020

Technical specifications:

Addressable manual call point is a unit manually operated to deliver a fire condition alarm signal to fire control panel IFS 7002.

The unit consist of base, a carrier unit with LED indicator, a cover, a glas with safety sticker and a test key.

The addressable manual call point is activated through a mechanic impact on the cover glass designated with arrows pint. To reset the unit remove the front cover and replace the activation glass.

The unit is provided with a built-in short circuit isolator for the signal loop. Communication between the addressable manual call point and the fire control panel is completed via the signal loop through UniTALK specialized communication protocol. Device address is programmable from the Fire Control Panel IFS 7002.

Products parameters:

Supply voltage	15 + 30 VDC
Environment type	Type A (for indoor application)
Operational temperature range	-10°C + +60°C
Relative humidity resistance	(93±3)% at 40°C
Degree of protection	IP 40
Dimensions	90 x 90 x 44 mm
Weight	0.200 kg
Material	red ABS

Essential characteristics	Harmonised technical specification		Performance
	EN 54-11:2001 EN 54-11/A1:2005	EN 54-17:2005 EN 54-17/AC:2007	
Nominal activation conditions / Sensitivity and Performance under fire conditions	cl. 4.3.2, 4.4, 4.7.1, 4.7.4=N/A, 5.2, 5.3	cl. 5.2	Pass
Operational reliability	cl. 4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 4.8, 5.4, 5.5	cl. 4	Pass
Durability of operational reliability: temperature resistance	cl. 5.7, 5.8=N/A, 5.9	cl. 5.4, 5.5	Pass
Durability of operational reliability: vibration resistance	cl. 5.14 to 5.17	cl. 5.9 to 5.12	Pass
Durability of operational reliability: humidity resistance	cl. 5.10, 5.11=N/A, 5.12, 5.19=N/A	cl. 5.6, 5.7	Pass
Durability of operational reliability: corrosion resistance	cl. 5.11=N/A, 5.13	cl. 5.8	Pass
Durability of operational reliability: electrical stability	cl. 5.6, 5.18	cl. 5.3, 5.13	Pass

History of certification

No.	Certificate No.	Description	Date of issue
1	1293-CPD-0072	Original certificate issued	February 6 th , 2008
2	1293-CPD-0215	Added place of factory	January 10 th , 2011
3	1293-CPD-0288	Changed place of factory	March 9 th , 2012
4	1293-CPR-0674	CPR certificate issued Change of address	January 20 th , 2020

Nová Dubnica, January 20th, 2020

Marek H u d á k
Director NB