



DECLARATION OF PERFORMANCE
According to Construction Products Regulation EU No. 305/2011
No 110 / 17.10.2022

1. Unique identification code of the product-type:

7000M

Batch number: see packaging of the product

2. Intended use/es:

Fire detection and fire alarm systems installed in buildings
Interactive addressable fire alarm panel

3. Manufacturer:

UniPOS Ltd.,
47 San Stefano Street, 5800, Pleven, Bulgaria

4. Authorised representative:

Not relevant

5. System/s of AVCP:

System 1

6. a) Harmonized standard:

EN54-2:1997 / AC:1999 / A1:2006 - Fire detection and fire alarm systems – Control and indicating equipment

EN 54-4:1997 / AC:1999 / A1:2002 / A2:2006 - Fire detection and fire alarm systems – Power supply equipment

Dedal notified body 1922 performed type testing and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control under system 1 and issued the EC certificates of conformity:

1922-CPR-1861

7. Declared performance

Essential characteristics	Performance	Harmonized Technical Specification
		EN54-2:1997 / AC:1999 / A1:2006
Performance under fire conditions	Pass	4, 5, 7
Response delay (response time to fire)	Pass	7.1, 7.7, 7.11, 7.12
Operational reliability	Pass	4, 5, 6, 7, 8, 9, 10, 12, 13, 14
Durability of operational reliability, Temperature resistance	Pass	15.4
Durability of operational reliability, Vibration resistance	Pass	15.6, 15.7, 15.15
Durability of operational reliability, Electrical stability	Pass	15.8, 15.13
Durability of operational reliability, Humidity resistance	Pass	15.5, 15.14

Essential characteristics	Performance	Harmonized Technical Specification
		EN54-4: 1997 / AC:1999 / A1:2002 / A2:2006
Performance of power supply	Pass	4, 5, 6
Operational reliability	Pass	4 to 8
Durability of operational reliability, temperature resistance	Pass	9.5
Durability of operational reliability, Vibration resistance	Pass	9.7, 9.8, 9.15
Durability of operational reliability, Electrical stability EMC	Pass	9.9
Durability of operational reliability, Humidity resistance	Pass	9.6, 9.14

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Hristo Dimitrov, Chief Executive
(name)

Pleven, 17.10.2022
(place and date of issue)

Signature _____

Chief Executive