



Graphical Monitoring Software

TYPE: UniPOS-Intellect

Brief User Manual



FIRE SCENARIO

Right-click on the pictogram for system control

"UniPos" 7002 FSA 1

System message
Configuration readed successfully.
02-01-17 14:30:30

- 1 Stop local zoomers
- 2 Switch to "Fire 2"
- 3 Increase time to "Fire 2"
- 4 Reset "fires"/"inputs"
- 5 Synchronize time
- 6 Supress/Activate Sounders

FIRE CONDITION ZONES IN FIRE : 3

1 Phase 2 Zone 001 Object: LOCAL	
Zone 001	
3 Phase 1 Zone 002 DIST #4	Time Fire Phase 2:120
Zone 00 2	

Devices in Fire TOTAL NUMBER : 4

1 Loop 01 Zone 001 Addr 001 Object: LOCAL	
Point 1.001	
2 Loop 02 Zone 003 Addr 001 Object: LOCAL	
Point 2.001	
4 Loop 01 Zone 002 Addr 002 Object: DIST #4	
Point 1.00 2	

Faults Tota l : 00000/00 00 * Failed Outputs : 00000
Disables Total : 000 Disabled Outputs : 000

4

6

2

1

3

Mode:DAY Loc Actinp 0000 11:11:08 Thu 11 Feb 2010

DISABLE SCENARIO

Right-click on the pictogram for Disable & Enable Device

FD7160 #5 1.19.1.5[1.19.1.5]

Device Armed
02-01-17 18:01:29

Disable device
Enable device

device address ← 1.19.1.5
sub-network ← 1.19
number of the panel on the sub-network ← 1
loop number ← 5
device address ← 1.19.1.5

local zone Floor 2 **1.19.5[1.19.5]**

Link last
23-12-16 16:31:20

zone number ← 5

Disable zone
Enable zone

FIRE CONTROL PANEL IFS7002
UniPOS

Faults total : 00000 Failed Outputs : 00000
Disables total : 003 Disabled outputs : 001

System functions/Disables / Devices(Zones) Go to :

Disabled Devices(Zones)- total Loop 1 002

Loop 1
DEVICE : 001 **DISABLED**

Point 1.001

0

1

2

3

4

5

6

7

8

9

C

Mode:DAY LOC Actinp 0000 12:58:22 Mon 22 Mar 2010

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

Right-click on the pictogram for Disable & Enable zone

Location of the event on the Map

FD704A #1 1.19.1.1[1.19.1.1]
 Output #1 1.19.1.1[1.19.1.1]
 FD7110 #4 1.19.1.4[1.19.1.4]
 FD7160 #5 1.19.1.5[1.19.1.5]
 Pos* 7002.FSA 1 - Chilinfgir[1]
 UniPOS

Panel #20
 All panels

FD7130 #2 1.19.1.2[1.19.1.2]
 FD7203IO #3 1.19.1.3[1.19.1.3]
 Input #1 1.19.1.3[1.19.1.3]
 Input #1 1.19.1.3[1.19.1.3]
 FD7130 #6 1.19.1.6[1.19.1.6]
 Local zone from device 2 1.19.5[1.19.5]
 Local zone from device 2 1.19.5[1.19.5]
 Local zone from device 2 1.19.5[1.19.5]

Event viewer 1

Source	Event	Region	Add. info	Date and time
Zone #23 1.8.23	Link lost			23.12.2016 r. 16:33:40
Zone #3 1.8.3	Link lost			23.12.2016 r. 16:33:40
Zone #4 1.8.4	Link lost			23.12.2016 r. 16:33:40
Zone #5 1.8.5	Link lost			23.12.2016 r. 16:33:40
Zone #6 1.8.6	Link lost			23.12.2016 r. 16:33:40
Zone #7 1.8.7	Link lost			23.12.2016 r. 16:33:40
Zone #8 1.8.8	Link lost			23.12.2016 r. 16:33:40
Zone #9 1.8.9	Link lost			23.12.2016 r. 16:33:40