



EVPU®

NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0912

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of March 9th, 2011* (the Construction products Regulation or CPR), this certificate applies to the construction product

Addressable - Conventional Adapter with built-in isolator 7201M

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

UniPOS Ltd.,
San Stefano str. 47, 5800 Pleven, Bulgaria
and produced in the manufacturing plant

UniPOS Ltd.,
San Stefano str. 47, 5800 Pleven, Bulgaria

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-18:2005, EN 54-18:2005/AC:2007,
EN 54-17:2005, EN 54-17:2005/AC:2007

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on July 25th, 2024 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



Nová Dubnica, July 25th, 2024

Michal Mišiak
Head of CB NB No. 1293

056143

EVPU a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, www.evpu.sk
Page 1 / 2 F COCV 7.7.12 Rev.1

Annex to Certificate No. 1293 - CPR - 0912 from July 25th, 2024

General information

The adapter is designed to support a conventional fire alarm line in the addressable loop at system 7000M.

Communication between the control panel and the adapter is carried out on by the signal loop through the specialized UniTALK information exchange protocol.

The adapter is powered by the signal loop. For short-circuit protection, there is a built-in isolator-on the signal loop and current protection on the conventional line.

Product parameters

Supply voltage	Signal loop
The maximum line voltage	V _{max} = 30 V DC
The nominal line voltage	V _{nom} = 24 V DC
The minimum line voltage	V _{min} = 18 V DC
Ingress protection	IP 30
Dimensions	92x60x22 mm
Weight	0,078 kg

Essential characteristics	Harmonised technical specification		Performance
	EN 54-18:2005 EN 54-18:2005/ AC:2007	EN 54-17:2005 EN 54-17:2005/ AC:2007	
Response delay (response time)	cl. 5.2	---	Pass
Performance under fire conditions	cl. 5.1.4	cl. 5.2	Pass
Operational reliability	cl. 5.1.4	cl. 4	Pass
Durability of operational reliability: temperature resistance	cl. 5.3, 5.4	cl. 5.4, 5.5	Pass
Durability of operational reliability: vibration resistance	cl. 5.8 to 5.11	cl. 5.9 to 5.12	Pass
Durability of operational reliability: humidity resistance	cl. 5.5, 5.6	cl. 5.6, 5.7	Pass
Durability of operational reliability: corrosion resistance	cl. 5.7	cl. 5.8	Pass
Durability of operational reliability: electrical stability	cl. 5.2, 5.12	cl. 5.3, 5.13	Pass



Nová Dubnica, July 25th, 2024

Michal Mišiak
Head of CB NB No. 1293